CERTIFICATE

Issued to:
Applicant:
Hadler GmbH
Fritzlarer Straße 19
34587 Felsberg, Germany

Manufacturer/Licensee:
Hadler GmbH
Fritzlarer Straße 19
34587 Felsberg, Germany

Product	:	LED control gear
Trade name	:	LUXTRONIC
Type	:	3 C 115 17 0

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
- a type test according to the standard EN 61347-1:2008; EN 61347-2-13:2014;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 997596

DEKRA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: 9 March 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3405076.01

DEKRA Certification B.V.

drs. G.J. Zoetbrood
Managing Director

H. Biener
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL

PRODUCTS
RvA C 001

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

product	:	LED control gear
trade name	:	LUXTRONIC
type	:	3 C 115 17 0
rated input voltage	:	220-240 V
nature of supply	:	ac or dc
rated frequency	:	0/50-60 Hz
temperature range	:	-25...+60°C
rated output current	:	350/500/700 mA
max output voltage	:	max 42 V
rated output	:	max 15 W
max case temperature	:	tc=75°C
power factor	:	0,95

Additional information

-SELV built-in LED constant current electronic control gear
-suited for being mounted in luminaires
-suitable for central battery emergency lighting systems

TESTS

Test requirements
Main test requirements:
EN 61347-1:2008 + A1:2011 + A2:2013
EN 61347-2-13:2014

Additional test requirements:
EN 62384:2006 + A1:2009

Test result
The test results are laid down in DEKRA test file 3405076.00.

Remarks
The component list is laid down in test report 3405076.50.

Conclusion
The examination proved that all test requirements were met.

Tested by : M. Müller

Checked by : J. Marggraf

Factory locations
Hadler GmbH
Fritzlarer Straße 19, 34587, Felsberg
Germany